

# TYPE APPROVAL CERTIFICATE

Certificate no.:  
**TAA00002VU**  
Revision No:  
**1**

**This is to certify:**  
**that the Temperature Sensor**

with type designation(s)  
**Protection tube: 21, 29, 165, 167, 211 Screwed joint: 166 Others: 14, 140, 147, 179, 130, 38**

issued to  
**Plöger Sensor GmbH**  
**Hamburg, Germany**

is found to comply with  
**DNV rules for classification – Ships, offshore units, and high speed and light craft**

## Application:

**Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.**

## Location classes:

<b>Temperature</b>	<b>B</b>
<b>Humidity</b>	<b>B</b>
<b>Vibration</b>	<b>B (see Application/Limitation)</b>
<b>EMC</b>	<b>N/A</b>
<b>Enclosure</b>	<b>C (see Application/Limitation)</b>

Issued at **Hamburg** on **2025-09-26**

This Certificate is valid until **2030-10-01**.

DNV local unit: **Hamburg – CMC North/East**

Approval Engineer: **Holger Jansen**



for **DNV**

This document has been digitally signed and will  
therefore not have handwritten signature

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.  
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

## Product description

### Resistance Thermometer

Temperature range: -50 up to 80 °C (14, 140 for cargo and other spaces)  
Temperature range: -50 up to 200 °C  
Measuring sensor: Pt 100 or 2 x Pt 100  
Measuring sensor: Pt 1000 or 2 x Pt 1000  
Measuring tolerance: IEC 60751 class AA or class B  
Max. insert length: 150 mm (29, 211)  
Max. insert length: 250 mm (21, 165, 166, 167)  
Max. insert length: 25 m (130, 147, 179)  
Max. insert length: 80m (38)  
Screw-in thread: G ½, G ¾, M 18x1.5  
Protection tube mat. No.: 1.4541, 1.4571, Teflon (147)

## Application/Limitation

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV Rules for Ships Pt.4 Ch.9 Control and Monitoring Systems.

Degree of protection: IP 54 (21, 29, 147, 165, 166, 167)  
IP 56 (14)  
IP 65 (140, 211)  
IP 66 (38, 130, 179)

Vibration test with 8 g (characteristic curve 2)

## Type Approval documentation

Test report: RMS no. 03-05/2000 (06.06.2000);  
Drawing no.: S 210-1(e), S210-2(e), S210-3(e) dated Nov. 2024,  
H 800-1(e) dated Nov. 2024,  
H 420-1(e) dated Nov. 2024,  
H 300-1(e) dated Nov. 2024,  
H 400-1(e), H400-2(e) dated Nov. 2024,  
H 110-1(e), H 110-2(e), H 110-3(e) dated Nov. 2024,  
H 200-1(e), S 200-2(e) dated Nov. 2024,  
H 110-2 dated Nov. 2024,  
H 107-38(e) dated Nov. 2024,

Type Approval Assessment Report issued at Hamburg – CMC North/East on 2025-09-24

## Tests carried out

Applicable tests according to Class Guidelines DNV-CG-0339, August 2021  
(see Application/Limitation.)

## Marking of product

Type  
Technical data (as under "Product Description")  
Serial Number

## Place of production

PLÖGER Sensor GmbH  
Feßlerstraße 3  
22083 Hamburg, GERMANY

### **Periodical assessment**

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE